



TAMIL NADU FIRE AND RESCUE SERVICES LICENCE

(Under section 13 of the Tamil Nadu Fire Service Act 1985 and
Tamil Nadu Fire Service Rule 1990 - Appendix-III)

Licence No: 29265/RFL/NMSB/2025

Dated: 16/12/2025

District Office,
Fire and Rescue Service,
Madurai District.

RENEWAL OF FIRE LICENSE

Ref: (1) Letter no:346690 from the Mangayarkarasi College of
Arts & Science for women, Dated: 23/11/2025

The Fire License is hereby **renewed** under section 13 of the Tamil Nadu Fire and Rescue Service Act 1985 for College in the name of M/s. Mangayarkarasi College of Arts & Science for Women at R.S.No:171, 172/1,2,3,4&5, Paravai, Madurai District. Consisting of Ground + Two floors with the Height of 9 Meters and total built-up area in 2962.14 Sqm within the jurisdiction of Madurai North Taluk based on the inspection was done by the Station Officer Tallakulam on 27/11/2025. Subject to the condition noted thereon and such other conditions as may be prescribed. This licence is valid for Three Years from 16/12/2025 to 15/12/2028 and should be renewed on 16/12/2028.

CONDITIONS

1. All firefighting equipment should always be kept in good working condition at all times and it should be as per the NBC 2016 part -IV maintained well and working in good condition. The trained personnel should always be available to operate the systems in case of any emergency.
2. Fire extinguishers should be installed and maintained as per IS 2190:2010
3. All Staff should be trained in preliminary firefighting as per G.O.No:713 Home (Police-17), Dated: 17.08.2005 with Fire and Rescue Services Department.
4. "Mock drill" should be periodically conducted.
5. Any addition and/or alteration of a permanent or temporary structure should be intimated to the Fire and Rescue Services Department.
6. Fire order / contingency plan / evacuation plan should be prepared and displayed in each floor at prominent places and "No Smoking" & "No Fire" boards should be displayed.
7. Emergency fire exit, staircases and doors should not be obstructed.
8. Good housekeeping should be maintained and dumping of waste materials and more should be avoided
9. All the electrical equipment, fitting, accessories and Wiring system should be maintained as per NBC 1997 Code of Practice for Fire Safety of Building (General) Electrical Installation should be followed.

Signature valid

Station Officer, Madurai, 1997
Southern Region, District Officer,
Home Department
Date:17-Dec-2025 18:20:51
District Officer,

Fire and Rescue Services
Madurai District



To: M/s. Mangayarkarasi College of Arts & Science for Women,
R.S.No:171, 172/1,2,3,4&5, Paravai, Madurai District.

Signature valid

Signed by: District Officer Madurai,
Southern Region - District Officer,
Home Department
Date:17-Dec-2023 18:20:51